

**DISTRICT WATER TESTING LABORATORY / MOBILE WATER TESTING LABORATORY DEPARTMENT OF W/S & SANITATION, PUNJAB**

**ANALYSIS REPORT OF WATER SAMPLE**

Particular of Sample

Sample No. 884

1. Name of Place <u>Jalandhar public school potaras</u>			
District..... <u>Jalandhar</u>	Block.....	Village.....	Depth.....
2. Source of the sample (Tick) Canal / Tubewell / Hand Pump / Any Other... <u>P.O</u>			
3. Name / Designation of the person who collected the sample			
4. (i) Date of Time of receipt in the Lab		<u>08-4-2024</u>	
(ii) Commencement of Test		<u>09-4-2024</u>	
5. CONDITIONS OF THE SAMPLE ..... SEALED\UNSEALED			

Sr. No.	Test	Desirable Limit	Permissible Limit	Result
1.	Turbidity (NTU) Max	1	5	
2.	Colour (Visual)	----	Un objectionable	<u>Colourless</u>
3.	Taste & Odour (Qualitative)	----	Un objectionable	<u>Ordinary</u>
4.	pH	6.5 to 8.5	No relaxation	<u>7.30</u>
5.	Total Dissolved Solids mg / l Max.	500	2000	<u>210</u>
6.	Calcium (Ca), mg/l. Max.	75	200	<u>37</u>
7.	Chloride mg/l. Max.	250	1000	<u>30</u>
8.	Total Alkalinity (as Ca, CO <sub>3</sub> ), mg/l, Max	200	600	<u>228</u>
9.	Total Hardness (as Ca, CO <sub>3</sub> ), mg/l, Max	300	600	<u>210</u>
10.	Residual Chlorine (as Cl), mg/l, Max,	0.2	1.0	-
11.	Fluorides (as F), mg/l, Max	1.0	1.5	-
12.	Nitrate (as NO <sub>3</sub> ), mg/l, Max	45	45	-
13.	Sulphate (as SO <sub>4</sub> ), mg/l, Max	200	400	-
14.	Iron (as (Fe), mg/l	0.3	0.3	-

**Bacteriological Parameters :**

- Test for Total Coliform by MPN method with MacConky Broth 10m/x.....
- Test for Fecal Coliform by MPN method with A1 Broth (Conducted if Total Coliform present) 1m/x.....
- H<sub>2</sub>S Kit ..... black colour observed/no change in colour 0.1m/x.....

**Report :**

- The water is potable / ~~not potable~~ .....With respect to tested parameters.....
- The following parameters are more than the 'acceptable' but less than the 'cause of rejection' limits. .....

The Report shall not be used for advertising or any legal purpose

This Report valid for 6 month

Miss Jasleen Kaur  
 Laboratory Incharge  
 District Water Testing Laboratory,  
 Jalandhar, Punjab